



Paul R. LePage  
GOVERNOR

STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0016

David Bernhardt  
COMMISSIONER

June 4, 2012  
Subject: **Steel Polymer Coated  
Corrugated Pipe**  
Location: **Grafton & Albany**  
State PIN: N/A  
**Amendment No. 1**

Dear Sir/Ms:

The following question has been received:

**Question:** Do you have a specific GAGE and CORRUGATION requirement for this pipe? If not, how much cover do you plan to have and what type of traffic will cross over the installed pipearch?

**Response:** The pipe arch should be AASHTO M246, 10 gauge, either 3x1 or 2-3/4x1/2 corrugations for 57" x 38" size.

Consider this information prior to submitting your bid on June 13, 2012.

Sincerely,

  
George Macdougall  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER